



EFFECTIS ERA AVRASYA
TEST VE BELGELENDİRME A.Ş.

Dilovası Organize San. Böl. 5.Kısım Fırat Cad.No:18 41455

Dilovası, Kocaeli / TURKEY

DENEY RAPORU

TEST REPORT



AB-0556-T

FTST251661

11-25

Müşterinin adı/adresi : AKSİS NONWOVENS TEKSTİL SANAYİ VE TİCARET A.Ş.
Customer name/address Göçerler Mah. Başkomutan Atatürk Cad. No:21,

Saray, Tekirdağ / TÜRKİYE

İstek numarası : EEA-25-001182-REV2
Order No.

Numunenin adı ve tarifi : Aksis Akustik Keçe – 6 mm
Name and identity of test sample

Numunenin kabul tarihi : 30.09.2025
The date of receipt of sample

Açıklamalar :
Remarks

Deneyin yapıldığı tarih : 14.10.2025
Date of test

Raporun sayfa sayısı : 3
Number of pages of the Report

Deney laboratuvarı olarak faaliyet gösteren Efectis Era Avrasya Test ve Belgelendirme A.Ş., TÜRKAK'tan AB-0556-T ile TS EN ISO/IEC 17025:2017 standardına göre akredite edilmiştir.

Efectis Era Avrasya Test ve Belgelendirme A.Ş. accredited by TÜRKAK under registration number AB-0556-T for EN ISO/IEC 17025:2017 as test laboratory"

Türk Akreditasyon Kurumu (TÜRKAK) deney raporlarının tanınması konusunda Avrupa Akreditasyon Birliği (EA) ve Uluslararası Laboratuvar Akreditasyon Birliği (ILAC) ile karşılıklı tanınma antlaşmasını imzalamıştır.

The Turkish Accreditation Agency (TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation (EA) and of the International Laboratory Accreditation (ILAC) for the Mutual recognition of test reports

Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metodları bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report

Mühür
Seal

Yayımlandığı Tarih
Date

Deney Sorumlusu
Person in charge of test

Onaylayan
Approval



04.11.2025

e-signed
Aslı SAKA

e-signed
Ali BAYRAKTAR

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

TEST REPORT

on Fire and Technical Characteristics

Our ref.: EEA-25-001182-REV2

Sponsor: AKSİS NONWOVENS TEKSTİL SANAYİ VE TİCARET A.Ş.
Göçerler Mah. Başkomutan Atatürk Cad. No:21, Saray, Tekirdağ / TÜRKİYE

TEST ITEM

Product name: Aksis Acoustic Felt – 6 mm

Manufacturing Plant: AKSİS NONWOVENS TEKSTİL SANAYİ VE TİCARET A.Ş.
Göçerler Mah. Başkomutan Atatürk Cad. No:21, Saray, Tekirdağ / TÜRKİYE

Composition : 50% Polyester Fiber, 50% Flame-Retardant Polyester Bico

Appearance : The white acoustic felt is a polyester-based material with a thickness of 6 mm and an area density of 1400 g/m².

Date of receipt of the sample: 30.09.2025

Date of realization of tests: 14.10.2025

Sampling: The samples were delivered by the sponsor.

TEST METHOD: EN ISO 11925:2020

Flame application time: 30 s

Conditioning: EN 13238:2010, Article 4.3.c, (23 ± 2) °C and % (50 ± 5) relative humidity

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid

MEASURED VALUES AND THE TEST RESULTS**SURFACE FLAME ATTACK**

Sample No.:	1	2	3	4	5	6
Ignition of the sample:	yes	yes	yes	yes	yes	yes
Reaching the mark:	no	no	no	no	no	no
Reaching the mark (s):	(-)	(-)	(-)	(-)	(-)	(-)
Ignition of the paper	no	no	no	no	no	no

Observations during tests: No flaming droplets were observed during tests.

Conclusion:

The test results relate to the behaviour of the test specimen of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product of use. The results of tests are concerned only with the subject of testing.

The protocol shall not be reproduced except in full without the written approval of the testing laboratory.

Brand, type, quality and dimension information of the components, when it is not possible to be verified by the laboratory, are given according to the sponsor's declaration and the responsibility belongs to the sponsor. The test specimens are tested as received from the sponsor (when the laboratory does not carry out sampling).

Bu rapor, laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz.

İmzasız ve mühürlü raporlar geçersizdir.

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature and seal are not valid